Petty, Joel

From: Banner, Ellen

Sent: Friday, July 08, 2016 3:24 PM

To: Banner, Ellen

Subject: FW: Vineland Ice and Storage

From: Harrington, Dwayne

Sent: Friday, July 08, 2016 10:42 AM

To: Lieber, Thomas <Lieber.Thomas@epa.gov>; Doyle, James <Doyle.James@epa.gov>; Regna, Jean <Regna.Jean@epa.gov>; Banner, Ellen <Banner.Ellen@epa.gov>; Mosher, Eric <Mosher.Eric@epa.gov>

Cc: pjohnson@gesoncall.com

Subject: Fwd: Vineland Ice and Storage

I received this this morning

Very serious concerns by a PE who inspected the building roof

Sent from my iPad

Begin forwarded message:

From: Jody DeMarco < jody.demarco@fc-na.com>

Date: July 8, 2016 at 10:01:43 AM EDT

To: harrington.dwayne@epa.gov Subject: Vineland Ice and Storage

Dwayne,

As a concerned professional engineer I want to discuss with you and make you aware of potential hazards at the Vineland Ice Storage facility.

In 2014 I was hired by the facilities insurance company to investigate the roof. I found the roof was in poor condition and required repairs and/or shoring.

According to a recent news article EPA is going to remove an estimated 12,000 pounds of ammonia from the refrigeration system. I am assuming this will basically defrost the facility and all the ice within the building will melt.

My concerns are:

- 1. Currently the failed roof members are encased in ice. A thaw of the building will likely result in collapse of the roof.
- 2. Collapse of the roof may cause the coolant coils attached to the roof framing to rupture thereby causing an uncontrolled escape of ammonia.
- 3. Thawing of the building will result in vast amounts of potentially contaminated water.

Please call me at 856-780-5658 or on my cell phone at <u>609-970-7665</u> to discuss.

Sincerely,

--

Jody DeMarco, P.E.

Forensic Consultants of North America, LLC 520 Fellowship Road, Suite A-110 Mount Laurel, NJ 08054 p: 856-780-5658 * f: 856-780-5659 jody.demarco@fc-na.com

